

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Mettler-Toledo GmbH
Industrie Nord, CH-8902 Urdorf

the Certificate No.: **Z00766** for the PROFIBUS Slave:

Product Name: Condi 7100 PA
Application CRC: Channel A: 0x Channel B: 0x
Revision: V 1.0; Stack 1.3 (09.12.98); SW: 2.0
GSD: METT7533.gsd
PA139750.gsd

This certificate confirms that the product has successfully passed the certification tests with the following scope:


<input checked="" type="checkbox"/>	DP-V0	MS0
<input checked="" type="checkbox"/>	DP-V1	MS2
<input type="checkbox"/>	DP-V2	
<input checked="" type="checkbox"/>	Profile	PA Devices V 3.0

Test Report Number: **036-01**
Authorized Test Laboratory: **ifak, Magdeburg**
Expiry date of Certificate: **June 9, 2008**


The tests were executed in accordance with the following documents:
"Test Specifications for Field Devices in accordance with PROFIBUS PA Profile for Process Control Devices, Version 3.0", April 2000 and "Test Specifications for PROFIBUS DP Slaves", February 2000.
This certificate is granted according to the document "Framework for testing and certification of PROFIBUS products".

Karlsruhe, July 19, 2005




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.


(Klaus-Peter Lindner)


(Prof. K. Bender)