



Transmitter O₂ 4220X

Technical Data

Contents	Technical Data O ₂ 4220X	2
	Terminal Assignments	5
	Certificate of Conformity	5
	Dimension Drawings	6

O₂ 4220X

Inputs	1 input for METTLER TOLEDO O ₂ sensors 1 input for Pt 100 / Pt 1000 / NTC 22 kΩ,	
Measuring Range	saturation	0,0 ... 600,0 % Air 0,0 ... 120,0 % O ₂
	concentration	0,0 µg/l ... 90,00 mg/l 0,0 ppb ... 90,0 ppm
	partial pressure	0 ... 1200 mbar
	air pressure	700 ... 1100 mbar
	temperature Pt	-50,0 ... +250,0 °C
Salinity Correction	temperature NTC	-20,0 ... +130,0 °C
	0,0 ... 45,0 kg	
Display	graphic LCD, 240 x 64 points main display additional display parameter display	character height approx. 20 mm character height approx. 6 mm 7 lines, character height approx. 4 mm
Display Options	main display: saturation concentration partial pressure temperature time	additional display: saturation [% Air]; [% O ₂] concentration [mg/l; µg/l] [ppm; ppb] [mbar] [°C] [mbar] [mA] [mA] [nA, µA] [h] [h, min] [t, m, j] [°C] [%] controller setpoint X _w
2-Channel Measurement Recorder*) (Option 448)	graphical representation of two measured values on the display, user defined for: % Air, % O ₂ , concentration, pO ₂ , °C, pressure, output 1, output 2, impedance, span and time feed user defined, recording selectable: snapshot; min, max, or average value, 500 measurements with time and date	
Languages*)	German, English, French, Italian, Spanish with Option 477: Swedish instead of Spanish	
Measuring Input	measuring current 0 ... 600 nA, resolution 10 pA polarization voltage -675 mV	
Measurement Error	measuring current	< 0,5 % of measured values ± 0,02 nA
Calibration	operating modes*) <ul style="list-style-type: none"> • automatic calibration in air-saturated water • automatic calibration in air • manual entry of saturation • manual entry of sensor data 	

*) adjustable

O₂ 4220X

Temperature Input	Pt 100 / Pt 1000 / NTC 22 kΩ, temperature sensor (tolerance adjustment)
Measuring Range	Pt100 / Pt1000 -50 ... +250 °C NTC 22 kΩ -20 ... +130 °C
Measuring Error	Pt100 / Pt1000 < 0,2 % of measured value, ± 0,3 K NTC (0 ... +100 °C) < 0,2 % of measured value, ± 0,3 K NTC (-20 ... +130 °C) < 0,2 % of measured value, ± 0,5 K
Temperature Compensation	non-linear, matching by METTLER TOLEDO O ₂ sensors Operating modes: • automatic with NTC 22 kΩ • manual
Output 1*) (Current Loop)	4 to 20 mA (22 mA), floating, power supply required user defined for % Air, % O ₂ , mg/l, µg/l, pO ₂ , °C output current user defined: linear, trilinear or function
Beginning/End of Scale*)	anywhere within range
Spans*)	saturation 10,0 ... 600,0 %, 2,0 ... 120,0 % O ₂ concentration ≥ 20,0 µg/l, min. 10 % of end of scale partial pressure 20 ... 1200 mbar temperature 10,0 ... 300,0 °C
Output Current Error	< 0,3 % of measured value ± 20 µA
Current Source Mode	4,00 mA to 22,00 mA
Input Ratings	O ₂ 4220X (EEx ib IIC): 14 to 30 V; I _{max} = 100 mA; P _{max} = 0,8 W
Output 2 (passive)* (Option 487)	0(4) to 20 mA (22 mA), floating, power supply required user defined for : % Air, % O ₂ , mg/l, µg/l, pO ₂ , °C output current user defined: linear, trilinear or function or as analog controller output (Option 353) anywhere within range
Beginning/End of scale*)	
Spans*)	saturation 10,0 ... 600,0 %, 2,0 ... 120,0 % O ₂ concentration ≥ 20,0 µg/l, min. 10 % of end of scale partial pressure 20 ... 1200 mbar temperature 10,0 ... 300,0 °C
Output Current Error	< 0,3 % of measured value ± 20 µA
Current Source Mode	0,00 mA to 22,00 mA
Input Ratings	O ₂ 4220X (EEx ib IIC): 1 to 30 V; I _{max} = 100 mA; P _{max} = 0,8 W
Defined as Switching Output Ratings	switching controller, limit value or alarm output O ₂ 4220X (EEx ib IIC): DC U _{max} = 30 V; I _{max} = 100 mA; P _{max} = 0,8 W, voltage drop: < 1 V
HART® Communication (Option 467)	digital communication via FSK ¹⁾ modulation of loop current (only output 1), point to point connection of multidrop (bus)*)

*) adjustable
1) frequency shift keying

O₂ 4220X

PI Controller (Option 483)	continuous controller via output 2 (Option 487) user-defined for % Air und % O ₂	
Clock	real-time clock with date, self-contained date format user-defined	
Records	for quality management documentation to ISO 9000	
Logbook (Option 354)	recording of	function activations, appearance and disappearance of warning and failure messages, with date and time
	storage capacity	200 entries available
Unit Self-Test	test of RAM, EPROM, EEPROM, display and keypad	
Calibration Record	all relevant data of the last calibration for documentation to GMP	
Data Retention in Case of Power Failure	parameters and calibration data > 10 years (EEPROM) logbook, statistics, cal record > 1 year (lithium battery) clock, reserve power > 1 Jahr (lithium battery) no battery replacement required (according NAMUR ³⁾ NE 32)	
Explosion Protection	ATEX II 2 (1) G EEx ib [ia] IIC T6	
RFI Suppression	to EN 50 081-1 and EN 50 081-2	
Immunity to ESD	to EN 50 082-1 and EN 50 082-2 and in accordance with NAMUR ³⁾ -NE 21 EMC recommendation for process and laboratory control equipment	
Environmental Temperature	operation ²⁾	-20 to +50 °C
	transport und storage	-20 to +70 °C
Enclosure	case with separate terminal compartment, suitable for outdoor mounting material: acrylonitrile butadiene styrene (ABS), front: polyester IP 65 protection	
Cable Glands	5 pcs M20 x 1.5	
Dimensions	refer to dimension drawing	
Weight	approx. 1,5 kg	

*) user-defined


1) frequency shift keying

2) at ambient temperature below 0 °C the readability of the display may be reduced,
however the unit functions are not impaired

3) German committee for measurement and control standards in the chemical industry

Terminal Assignments

O₂ 4220X



Physikalisch-Technische Bundesanstalt
Braunschweig und Berlin

PTB

EC-TYPE-EXAMINATION CERTIFICATE
(Translation)

(1) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - Directive 94/9/EC

(2) EC-type-examination Certificate Number:

PTB 03 ATEX 2190

(3) Equipment: O₂-Transmitter type A220X Opt. ...
 (4) Manufacturer: Weller Technik AG
 (5) Address: Im Hochfelder 18, CH-8802 Uetendorf

(6) This equipment and any acceptable options thereof are specified in the schedule to this certificate and the documents thereto referred to.

(7) The Physikalisch-Technische Bundesanstalt, certified body No. C102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that the equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 03-2020.

(8) Compliance with the Essential Health and Safety Requirements has been assessed by compliance with:
EN 60016-1:1997 + A1 + A2 **EN 60039-1:1994**

(9) If the sign "K" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(10) The EC-type-examination Certificate relates only to the design and construction of the specified equipment in accordance with Directive 94/9/EC. Further requirements of the Directive apply to the manufacture and supply of the equipment.

(11) The marking of the equipment shall include the following:
II 2 (1) G Ex n [ia] IIC T9

Zertifizierungsstelle Explosionsschutz
By order of

Dr.-Ing. U. Johnenmeyer
Registrierungsleiter

PTB
Braunschweig, January 24, 2001

sheet 1/3

EC-type-examination Certificates without signature and official stamp are invalid. The certificates may be issued only without signature. Certificates otherwise are only valid if accompanied by the Physikalisch-Technische Bundesanstalt. In case of dispute, the German law shall prevail.
Physikalisch-Technische Bundesanstalt | Braunschweig, 06114 Braunschweig

Certificates

Physikalisch-Technische Bundesanstalt
Braunschweig und Berlin

PTB

SCHEDULE

(13) EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2190

(14) Description of equipment:

The O₂-transmitter type 4220X Opt. ... is used preferably for detecting and processing medical technical questions and is equipped with an input for the partial pressure measurement of oxygen and an input for the measurement of temperature.

The application occurs within the hazardous area.

The maximum permissible ambient temperature is 50 °C.

Electrical data:

Loop measuring circuit (RL 8, 10): type of protection Intrinsic Safety (IIS) & IIC
only for connection to a certified intrinsically safe circuit
maximum values:
 $U_s = 30 \text{ V}$
 $I_s = 100 \text{ mA}$
 $P_s = 0.8 \text{ W}$
 $G_s = 22 \text{ nF}$
 $L_s = \text{negligibly low}$

Output circuit 2 (RL 11, 12): type of protection Intrinsic Safety (IIS) & IIC
only for connection to a certified intrinsically safe circuit
maximum values:
 $U_s = 30 \text{ V}$
 $I_s = 100 \text{ mA}$
 $P_s = 0.8 \text{ W}$
 $G_s = 40 \text{ nF}$
 $L_s = \text{negligibly low}$

O₂-measuring circuit (RL 1, 3, 4, 5): type of protection Intrinsic Safety (IIS) & IIC
maximum values:
 $U_s = 15 \text{ V}$
 $I_s = 1.02 \text{ mA}$
 $P_s = 2 \text{ mW}$
 $R_s = 3.5 \text{ kΩ}$
 $\text{linear characteristic:}$
 $G_s = 620 \text{ nF}$
 $L_s = 1 \text{ nH}$

sheet 2/3

EC-type-examination certificates without signature and official stamp are invalid. The certificates may be issued only without signature. Certificates otherwise are valid if accompanied by the Physikalisch-Technische Bundesanstalt. In case of dispute, the German law shall prevail.

Physikalisch-Technische Bundesanstalt
Braunschweig und Berlin

PTB

SCHEDULE TO EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2190

G_s = 22 nF
 L_s = negligibly low

Temperature measuring circuit (RL 6, 7, 9): type of protection Intrinsic Safety (IIS) & IIC
 maximum values:
 $U_s = 15 \text{ V}$
 $I_s = 2 \text{ mA}$
 $P_s = 4 \text{ mW}$
 $R_s = 1.0 \text{ kΩ}$
 linear characteristic:
 $G_s = 475 \text{ nF}$
 $L_s = 1.8 \text{nH}$
 $C_s = 30 \text{ pF}$
 $L_s = \text{negligibly low}$

R_s: for connection to the equivalent bonding system

The loop measuring circuit is safety electrically isolated from the other intrinsically safe circuits up to a voltage of 90 V.

The output circuit 2 is safety electrically isolated from the G_s- and from the temperature measuring circuit up to a voltage of 90 V.

The O₂-measuring circuit and the temperature measuring circuit are electrically interconnected.

(16) Test report PTB Ex 03-2020

(17) Special conditions for safe use:

(18) General description of safety requirements met by the standards mentioned above:

Zertifizierungsstelle Explosionsschutz
By order of

Dr.-Ing. U. Johnenmeyer
Registrierungsleiter


PTB
Braunschweig, January 24, 2001

sheet 2/3


EC-type-examination Certificates without signature and official stamp are invalid. The certificates may be issued only without signature. Certificates otherwise are valid if accompanied by the Physikalisch-Technische Bundesanstalt. In case of dispute, the German law shall prevail.

Dimension Drawings

O₂ 4220X




ZU 0157 protective hood, ZU 0136 mounting plate and ZU 0125 bracket kit



Note: All dimensions in millimeters

O₂ 4220X


ZU 0158 Protective Case




Note: All dimensions in millimeters

O₂ 4220X

Unit with Lockable Control-Panel Cover (Opt. 432)



ZU 0158 protective case with ZU 0220 bracket kit for protective case



Management System
certified according to
ISO 9001 / ISO 14001



<http://www.mtpro.com>

Sales and Service:

Mettler-Toledo GmbH, Process Analytics
Industrie Nord, CH-8902 Urdorf, Switzerland

Tel.: +41 44 736 22 11
Fax: +41 44 736 26 36

Subject to technical changes. © Mettler-Toledo GmbH 11/04.
Printed in Switzerland. 52 120 793